



### Does the building require a sprinkler system?



### Does the building require on-site stored water for fire-fighting?



Look up the following section in the Alberta Building Code (2019) 3.2.2.20–3.2.2.90 according to the building’s height and major occupancy:

- 3.2.2.25 – Group A, Division 2, up to 2 Storeys
- 3.2.2.28 – Group A, Division 2, 1 Storey
- 3.2.2.30 – Group A, Division 3, up to 2 Storeys
- 3.2.2.32 – Group A, Division 3, 1 Storey, increased area
- 3.2.2.34 – Group A, Division 3, 1 Storey
- 3.2.2.35 – Group A, Division 4
- 3.2.2.60 – Group D, up to 3 storeys
- 3.2.2.62 – Group D, up to 2 storeys
- 3.2.2.66 – Group E, up to 3 storeys
- 3.2.2.68 – Group E, up to 2 storeys
- 3.2.2.73 – Group F, Division 1, 1 storey
- 3.2.2.76 – Group F, Division 2, up to 3 storeys
- 3.2.2.78 – Group F, Division 2, up to 2 storeys
- 3.2.2.83 – Group F, Division 3, up to 3 storeys
- 3.2.2.85 – Group F, Division 3, up to 2 storeys
- 3.2.2.87 – Group F, Division 3, 1 storey
- 3.2.2.89 – Group F, Division 3, 1 storey, low fire load
- 3.2.2.90 – Group F, Division 3, storage garage

Is the building to be constructed in accordance with any of the above?

**Table 3.1.2.1. Major Occupancy Classification**  
Forming Part of Sentences 3.1.2.1.(1) and 3.1.2.2.(1)

Group	Division	Description of Major Occupancies
A	1	Assembly occupancies intended for the production and viewing of the performing arts
A	2	Assembly occupancies not elsewhere classified in Group A
A	3	Assembly occupancies of the arena type
A	4	Assembly occupancies in which occupants are gathered in the open air
B	1	Detention occupancies
B	2	Treatment occupancies
B	3	Care occupancies
C	—	Residential occupancies
D	—	Business and personal services occupancies
E	—	Mercantile occupancies
F	1	High-hazard industrial occupancies
F	2	Medium-hazard industrial occupancies
F	3	Low-hazard industrial occupancies

THIS FLOWCHART HAS BEEN PUBLISHED AS PUBLIC SERVICE. IT IS NOT INTENDED TO REPLACE PROFESSIONAL ENGINEERING ADVICE. REFER TO THE ALBERTA BUILDING CODE FOR FURTHER REQUIREMENTS, DETAILS, AND EXCEPTIONS. 908 ENGINEERING ASSUMES NO RESPONSIBILITY FOR THE CONTENT HEREIN.

REV.	DATE	DESCRIPTION
3	23 OCT 2019	UPDATED TO NATIONAL BUILDING CODE - 2019 ALBERTA EDITION
2	03 NOV 2017	UPDATED STANDATA REFERENCE TO ABC(2014)
1	09 OCT 2015	UPDATED ABC(2006) REFERENCES TO ABC(2014)
0	31 JULY 2014	ISSUED FOR PUBLIC USE



PO Box 20020 Red Deer, AB T4N 6X5  
Phone: 403.986.2939 Web: 908eng.com

PROJECT:  
**AUTOMATIC FIRE SUPPRESSION & AVAILABLE WATER SUPPLY REQUIREMENTS**

FILE NO:  
**N/A**

DWG NO:  
**SP**

SPRINKLER SYSTEM REQUIRED?  
ON-SITE STORED WATER FOR FIRE-FIGHTING?

1 OF 1

DRAWN: COB      CHECKED: COB      DATE: 23 OCT 19